HLS Type Roller plunger type



Refer to the specifications of the manufacturer for the basic performance of the limit switches.

HLS Type Roller lever type





Refer to the specifications of the manufacturer for the basic performance of the limit switches.

PS Type Roller lever type



Refer to the specifications of the manufacturer for the basic performance of the limit switches.

MLS Type Seal roller plunger type



Refer to the specifications of the manufacturer for the basic performance of the limit switches.

OLS Type Roller plunger type

With wire connecting box







Refer to the specifications of the manufacturer for the basic performance of the limit switches.

Specifications in the catalog are subject to change without notice due to improvements in performance and quality.

20

10

H ຊ

8 ຊີ

135

(8)(6)

(9)

2

2

165

35

(8)(6)(3)

NCS-302-PM

65

OLS Type = Seal roller plunger type



Refer to the specifications of the manufacturer for the basic performance of the limit switches.

LST Type



1	Switch box
2	Dog
3	Slide bar
4	Guide bar
5	S side plate
6	G side plate
0	C blacket parts
8	Limit switches: Equivalent to Model Z-15GW22-B (OMRON)

Dimensional table (Unit: mm						
Model	Stroke	Box length L				
LST-250	Up to 250	360				
LST-300	Up to 300	410				
LST-350	Up to 350	460				
LST-400	Up to 400	510				
LST-450	Up to 450	560				
LST-500	Up to 500	610				
L	1	1				

Please contact us if internal wiring of switch box is required. Refer to the specifications of the manufacturer for the basic performance of the limit switches.





Note 1) Please indicate the direction (L/S/R) of the wire cord outlet port. Note 2) When adjusting the dog, all adjustments should made after loosening the set screws (2 pcs). Note 3) Refer to the specifications of the manufacturer for the basic performance of the micro switches.

CLS Type



Refer to the specifications of the manufacturer for the basic performance of the limit switches. Specifications in the catalog are subject to change without notice due to improvements in performance and quality.

Caution for handling the Reed Switch Built-in Type

Reed switch built-in cylinder (lock in place by adjusting screw nut-type)

[Features]

- Compared to the external limit switch device, it takes very little space and it fits compactly within the cylinder's length.
- · Having a built-in Reed switch, it is not affected by external magnetic fields.
- · It is not affected by external damaging conditions such as mold release agents, water, etc.
- · Stroke adjustment is extremely simple.
- Since the lock in place mechanism has been improved by adding a nut to the adjusting screw, it is even less likely to be loosened by unexpected impacts.
- The orientation of the cord can be adjusted at 360°.

[Reed Switch]

Applicable stroke	Adjustable range	Practical operating range	
15	9	6 ~ 15	
20	12	8 ~ 20	
30	12	18 ~ 30	
40	12	28 ~ 40	
50	12	38 ~ 50	

(Can be manufactured up to 200 mm.)

- * When ordering, by inserting "R-" in front of the cylinder model, you will ensure that a "lock in place by adjusting nut-type" Reed switch will be installed.
- * For special cases, we also sell a "flat screw-type" which prevents the stroke-adjustment screw from coming off. If you wish a "flat screw-type," please specify so.

Normal model Ex.) BCNFA15C30N30 -

Reed switch built-in model R-BCNFA15C30N30

If choosing the above model, since it comes automatically equipped with reed switch device for 30 strokes, please use the cylinder in the actual stroke range of between 18 to 30 mm. For actual strokes other than between 18 to 30 mm, please contact us.

[Caution]

- · Attention should be paid not to damage body, cord, connectors, etc.
- Please use voltage and current, within the prescribed values.
- If used in a location where the cord will be subject to tension or repetitive stress, It must be fixed to prevent it from breaking. When doing so, avoid applying excessive force to the cord.
- · Refrain from using it in environments where chemicals or similar substances may adhere to the cord.
- Please do not remove the cable gland (skin top) attached to the body.
- Moreover, please refrain from peeling off the seal either.
- Since the proper torque value for installing the reed switch onto the cylinder body is set at 49.0 N/m (5.0 kgf/m), keep this in mind when assembling it.

Method for checking Reed switch operation

* This is a method for determining the stroke with a single-article reed switch.



st	A Dimensional (mm)
15	51.5
20	56.5
30	66.5
40	76.5
50	86.5
60	96.5
70	106.5
80	116.5
90	126.5
100	136.5
110	146.5
120	156.5
130	166.5
140	176.5
150	186.5
160	196.5
170	206.5
180	216.5
190	226.5
200	236.5

[Stroke adjustment method]

Tools required for the adjustment

- 1.5 mm Hexagonal wrench (for adjusting the cable direction)
- 2 mm Hexagonal wrench
- \cdot Spanner for M4 (7 mm)
- * From the perspective of reducing environmental impact, we will not include in the shipment the tools required for adjustments. Thank you for your understanding.
- * A simple continuity tester equipped with a buzzer and a luminous indicator is sold separately as an optional.

\sim Adjustment method \sim

- 1) Make the cylinder move to back and forth several times by hydraulic or pneumatic pressure to ensure that it's operating normally. * This should initially be done at low pressure.
- 2) Loosen the screw which locks the cord in place with the 1.5 mm hex. Wrench and adjust the orientation of the cord.
- 3) Set the rod piston in the predetermined forward-side (IN) position.
- 4) Connect the forward-side (IN) cables (white and green) to the tester.
- 5) When adjusting the stroke, loosen the nut while keeping the adjusting screw in place with the 2mm hex wrench. With the nut loosened, turn the adjusting screw once to the right (counter-clockwise) until the end.
- 6) Next, turn the adjusting screw to the right (clockwise) and adjust it until conduction is established.
- After conduction is established, ensure sure to leave room for 4 further turns (2.8 mm).

Stroke adjustment screw (one revolution = 0.7 mm stroke)

- * Turn clockwise • • Setting stroke will be shortened (The built-in switch comes forward)
- * Turn counterclockwisee • Setting stroke will be lengthened (The built-in switch moves backward)
- Note: at the time of shipment adjustments have been made to guarantee conduction approx. 2.8 mm in front of both the forward side (IN) and the backward side (OUT).
 - In principle, backward-side (OUT) adjustment is not required.

(Since adjustments are possible up to 4 mm, by turning the stroke adjustment as described in the above steps 5 and 6, the adjustment method will be reversed.)

- 7) After completing the adjustment, tighten the nut with a spanner while keeping the adjusting screw in place with the 2 mm hex wrench. * If the nut is tightened without securing the adjusting screw in place with the wrench, the adjustment screw will turn together
 - with the nut and its position will be off.



[Reed Switch Specifications]

Maximum switching voltage	ge	-		100V(DC/AC)	
Rated switching current	Ι	DC/AC	100V	30mA	
	Π	DC/AC	24V	100mA	
Insulation resistance				more than 20 $M\Omega$	
Hysteresis				Approx. 0.7 mm	
Resonance frequency				2750±250Hz(Single Reed Switch)	
Operating temperature range				-20°C ~ 100°C	
011				Dynamical pressure 21MPa(210kgf/cm ²)	
Oil proof pressure				Static pressure 35MPa(210kgf/cm ²)	
Hydraulic oil				General mineral hydraulic oil (can be used for water glycol compounds)	
Electrical operating life				DC24V-200mA More than 500,000 times	
Cable				24AWG (0.21mm ²)×4 cores with bundled shield Outside diameter \Rightarrow 5.0 mm	
Cable length				1000mm	
Minimum cable bend radi	JS			20mm	
Measurement length				15, 20, 30, 40, 50mm(Up to 200 mm can be made.)	
Adjustable range				12mm(Backward side: 4 mm)/9mm(Backward side: 4 mm)[15st only]	
Stroke adjustment				Screw type (A single turn: 0.7 mm)	
Protection standard				IP67	

(Other)

- Standard cable length is 1000 mm.
- (Can be extended by attaching the connector. /the cord can also be extended without connecting it.)
- · If you specify the length of the cord for connecting to the machine as well as the connectors, we will take care of the installation.
- When performing stroke adjustment, a convenient simple continuity tester is sold separately as an optional.

Dimension



Caution for handling the Reed Switch